

कार्यालय सहायक यंत्री
लोकस्वा. यांत्रिकी विभाग, उपखण्ड-हरदा

दूरभाष-07577-223212-फेक्स 226777. ईमेल-eephedhar@mp.nic.in

क्रमांक 15/स.यं./तक/लोक स्वा. यां. वि./2024-25 हरदा, दिनांक 26/4/24

प्रति,

ST. JUDES CO. ED
School Chhipavad
Khirkiya Distt. Harda

विषय - पेयजल परीक्षण रिपोर्ट प्रेषित करने बावत ।

उपरोक्त विषयान्तर्गत लेख है, की आपके द्वारा प्रेषित पेयजल नमूने का जल परीक्षण कर रिपोर्ट आपकी ओर प्रेषित है।

संलग्न :- जल परीक्षण रिपोर्ट

सहायक यंत्री

लोक स्वा. यां. विभाग,
उपखण्ड-हरदा
Public Health Engg. Sub Dvn.
HARDA-461 331

क्रमांक...../स.यं./तक/लोक स्वा. यां. वि./2024-25 हरदा, दिनांक

प्रतिलिपि :- कार्यपालन यंत्री लो.स्वा.यां.वि. खण्ड हरदा की ओर सूचनार्थ प्रेषित ।



MANAGER
ST. JUDES CO-ED SCHOOL
Chhipavad, Khirkiya-461441
Distt : Harda (M.P.)



PRINCIPAL
ST. JUDES COED SCHOOL
Chhipavad Khirkiya-461441
Distt-HARDA(M.P.)
SCHOOL CODE-582072

सहायक यंत्री

लोक स्वा. यां. विभाग,
उपखण्ड-हरदा
Public Health Engg. Sub Dvn.
HARDA-461 331

PUBLIC HEALTH ENGINEERING DEPARTMENT, DIV HARDA

DISTRICT WATER TESTING REPORT


Report No.- 15	Date- 26/4/24	District -Harda	Block- Khirkiya
Ref No.- 86	Date- 24/4/24	Location and Village	
To Assistant Engineer Public Health Engg Sub Division Harda (M.P.)		J. ST. JUDES COED SCHOOL Chhipavad Khirkiya District -Harda (M.P.)	
Sample Collected by-	106 OFF		
Date Of Collection-	24/4/24		
Source-	TUBE WELL		
Date of Sample Receipt-	24/4/24		
Date of sample Testing-	24/4/24		
Test conducted By-	Lab Staff		

As Per BIS 10500:2012 Reaffirmed in Fed 2021 for Drinking water

S.no	Characteristics	Unit	Acceptable	Cause of Rejection	Result				
					1	2	3	4	5
PHYSICAL TEST									
1	Turbidity	NTU	1	5	1.4				
2	PH	-	6.5to8.5	6.5to8.5	7.08				
3	Conductivity/TDS	Umhos/cm	-	-	1015				
4	TDS	Mg/l	500	2000	609				
CHEMICAL TEST									
5	Alkalinity	Mg/l	200	600	126				
6	chloride	Mg/l	250	1000	74.1				
7	Total hardness	Mg/l	200	600	298				
8	Calcium	Mg/l	75	200	73.6				
9	Magnesium	Mg/l	30	100	22.56				
10	Iron	Mg/l	0.3	1	0.12				
11	Nitrate	Mg/l	45	45	10				
12	Fluoride	Mg/l	1	1.5	0.5				
13	Sulphate	Mg/l	200	400	50.23				
14	Mangnese	Mg/l	0.1	0.3	0.0				
15	Chlorine	Mg/l	0.2	1	-				
BACTERIOLOGICAL TEST									
16	Total Coliform	Per100ml	0	-	NA				
17	E.coli or thermo tolerant coliform	Per100ml	0	-					

- Note- 1. Not to be Produced at Court of Law.
 2. As above result compared with BIS 10500:2012
 3. Sample are not collected by us.


 MANAGER
ST. JUDES CO-ED SCHOOL
 Chhipavad, Khirkiya-461441
 Distt : Harda (M.P.)


 PRINCIPAL
ST. JUDES COED SCHOOL
 Chhipavad Khirkiya-461441
 Distt-HARDA(M.P.)
 SCHOOL CODE-582072


 CHEMIST
 Public Health Engg. Sub Division
 Harda (M.P.)
 Public Health Engineering Department
 Harda (M.P.)

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 15Dated: 26/4/24

It is certified that an inspection team headed by Rani Belekay (chemist)
(Name of Officers with designation) from P.H.E.D SUB Div. Harda

PHED inspected the **ST JUDES COED SCHOOL, CHHIPAVAD, KHIRKIYA, DIST.- HARDA, MP** on 24/4/24
and on the basis of Water Test Report (Attached) bearing no. 15 dated 24/4/24
of Public Health Engineering Department Harda (M.P.) (PHED Lab) certified that
the **ST JUDES COED SCHOOL, CHHIPAVAD, KHIRKIYA, DIST.- HARDA, MP** has safe drinking water facilities
for the students and members of staff of the institution. School is also maintains the hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 year

Signature with seal

Name

Designation

Name & address of the office/Department: - P.H.E.D Harda

CHEMIST

Public Health Engineering Department
Harda (M.P.):- Rani Belekay:- Chemist


PRINCIPAL
ST. JUDES COED SCHOOL
Chhipavad Khirkiya-461441
Distt-HARDA(M.P.)
SCHOOL CODE-582072

To,

ST JUDES COED SCHOOL,

CHHIPAVAD, KHIRKIYA, DIST.- HARDA, MP

(Name and address of the institution)

MANAGER

ST. JUDES CO-ED SCHOOL
Chhipavad, Khirkiya-461441
Distt : Harda (M.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies